

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO: 003

NAME: 2002 WELL

CLASS: CTGA

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES	
2100508 - 003	2100508 MUIR BEACH COMMUNITY	003	2002 WELL							
	GP SECONDARY/GP									
	00440	BICARBONATE ALKALINITY	120.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00916	CALCIUM	14.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00445	CARBONATE ALKALINITY	< 1.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00940	CHLORIDE	32.0000	MG/L	500.000	-----	2014/03/06	36	2017/03	
	00081	COLOR	10.0000	UNITS	15.000	-----	2014/03/06	36	2017/03	
	01042	COPPER	< 50.0000	UG/L	1000.000	50.000	2014/03/06	36	2017/03	
	38260	FOAMING AGENTS (MBAS)	< .0500	MG/L	0.500	-----	2014/03/06	36	2017/03	
	00900	HARDNESS (TOTAL) AS CaCO3	93.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	71830	HYDROXIDE ALKALINITY	< 1.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	01045	IRON	< 100.0	UG/L	300.000	100.000	2016/06/22	12	2017/06	
	00927	MAGNESIUM	14.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	01055	MANGANESE	85.0	UG/L	50.000	20.000	2016/06/22	3	2016/09	
	00086	ODOR THRESHOLD @ 60 C	< 1.0000	TON	3.000	1.000	2014/03/06	36	2017/03	
	00403	PH, LABORATORY	6.9000		-----	-----	2014/03/06	36	2017/03	
	01077	SILVER	< 10.0000	UG/L	100.000	10.000	2014/03/06	36	2017/03	
	00929	SODIUM	20.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00095	SPECIFIC CONDUCTANCE	330.0000	US	1600.000	-----	2014/03/06	36	2017/03	
	00945	SULFATE	13.0000	MG/L	500.000	0.500	2014/03/06	36	2017/03	
	70300	TOTAL DISSOLVED SOLIDS	190.0000	MG/L	1000.000	-----	2014/03/06	36	2017/03	
	82079	TURBIDITY, LABORATORY	2.7000	NTU	5.000	0.100	2014/03/06	36	2017/03	
	01092	ZINC	< 50.0000	UG/L	5000.000	50.000	2014/03/06	36	2017/03	
	IO INORGANIC									
	01105	ALUMINUM	< 50.0000	UG/L	1000.000	50.000	2014/03/06	36	2017/03	
	01097	ANTIMONY	< 6.0000	UG/L	6.000	6.000	2014/03/06	36	2017/03	
	01002	ARSENIC	< 2.0000	UG/L	10.000	2.000	2014/03/06	36	2017/03	
	81855	ASBESTOS	ND	MFL	7.000	0.200	2016/06/22	108	2025/06	
	01007	BARIIUM	< 100.0000	UG/L	1000.000	100.000	2014/03/06	36	2017/03	
	01012	BERYLLIUM	< 1.0000	UG/L	4.000	1.000	2014/03/06	36	2017/03	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO:

NAME: 2002 WELL

CLASS: CTGA

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES	
2100508 - 003	IO INORGANIC									
	01027	CADMIUM	<	1.0000 UG/L	5.000	1.000	2014/03/06	36	2017/03	
	01034	CHROMIUM (TOTAL)	<	1.0000 UG/L	50.000	10.000	2014/03/06	36	2017/03	
	01032	CHROMIUM, HEXAVALENT	<	.0000 UG/L	10.000	1.000	2014/08/28	36	2017/08	
	00951	FLUORIDE (F) (NATURAL-SOURCE)		.1900 MG/L	2.000	0.100	2014/03/06	36	2017/03	
	71900	MERCURY	<	1.0000 UG/L	2.000	1.000	2014/03/06	36	2017/03	
	01067	NICKEL	<	10.0000 UG/L	100.000	10.000	2014/03/06	36	2017/03	
	A-031	PERCHLORATE	<	4.0000 UG/L	6.000	4.000	2014/03/06	36	2017/03	
	01147	SELENIUM	<	5.0000 UG/L	50.000	5.000	2014/03/06	36	2017/03	
	01059	THALLIUM	<	1.0000 UG/L	2.000	1.000	2014/03/06	36	2017/03	
	NI NITRATE/NITRITE									
	00618	NITRATE (as N)	<	0.4 mg/L	10.000	0.400	2016/06/22	12	2017/06	
	00620	NITRITE (AS N)	<	400.0000 UG/L	1000.000	400.000	2014/03/06	36	2017/03	
	RA RADIOLOGICAL									
	01501	GROSS ALPHA		.2270 PCI/L	15.000	3.000	2010/06/21	108	2019/06	
	S1 REGULATED VOC									
	34506	1,1,1-TRICHLOROETHANE	<	0.5 UG/L	200.000	0.500	2016/06/22	72	2022/06	
	34516	1,1,2,2-TETRACHLOROETHANE	<	0.5 UG/L	1.000	0.500	2016/06/22	72	2022/06	
	34511	1,1,2-TRICHLOROETHANE	<	0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34496	1,1-DICHLOROETHANE	<	0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34501	1,1-DICHLOROETHYLENE	<	0.5 UG/L	6.000	0.500	2016/06/22	72	2022/06	
	34551	1,2,4-TRICHLOROBENZENE	<	0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34536	1,2-DICHLOROBENZENE	<	0.5 UG/L	600.000	0.500	2016/06/22	72	2022/06	
	34531	1,2-DICHLOROETHANE	<	0.5 UG/L	0.500	0.500	2016/06/22	72	2022/06	
	34541	1,2-DICHLOROPROPANE	<	0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34561	1,3-DICHLOROPROPENE (TOTAL)	<	0.5 UG/L	0.500	0.500	2016/06/22	72	2022/06	
	34571	1,4-DICHLOROBENZENE	<	0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34030	BENZENE	<	0.5 UG/L	1.000	0.500	2016/06/22	72	2022/06	
	32102	CARBON TETRACHLORIDE	<	0.5 UG/L	0.500	0.500	2016/06/22	72	2022/06	
	77093	CIS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	6.000	0.500	2016/06/22	72	2022/06	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO:

NAME: 2002 WELL

CLASS: CTGA

STATUS: Active

PCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES
2100508 - 003	S1 34423	DICHLOROMETHANE	< 0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34371	ETHYLBENZENE	< 0.5 UG/L	300.000	0.500	2016/06/22	72	2022/06	
	46491	METHYL-TERT-BUTYL-ETHER (MTBE)	< 3.0 UG/L	13.000	3.000	2016/06/22	36	2019/06	
	34301	MONOCHLOROBENZENE	< 0.5 UG/L	70.000	0.500	2016/06/22	72	2022/06	
	77128	STYRENE	< 0.5 UG/L	100.000	0.500	2016/06/22	72	2022/06	
	34475	TETRACHLOROETHYLENE	< 0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34010	TOLUENE	< 0.5 UG/L	150.000	0.500	2016/06/22	72	2022/06	
	34546	TRANS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	10.000	0.500	2016/06/22	72	2022/06	
	39180	TRICHLOROETHYLENE	< 0.5 UG/L	5.000	0.500	2016/06/22	72	2022/06	
	34488	TRICHLOROFLUOROMETHANE	< 5.0 UG/L	150.000	5.000	2016/06/22	72	2022/06	
	81611	TRICHLOROTRIFLUOROETHANE (FREON 113)	< 10.0 UG/L	1200.000	10.000	2016/06/22	72	2022/06	
	39175	VINYL CHLORIDE	< 0.5 UG/L	0.500	0.500	2016/06/22	72	2022/06	
	81551	XYLENES (TOTAL)	< 0.5 UG/L	1750.000	0.500	2016/06/22	72	2022/06	
S2 REGULATED SOC									
	39045	2,4,5-TP (SILVEX)	< .0000 UG/L	50.000	1.000	2014/03/06	108	2023/03	
	39730	2,4-D	< .0000 UG/L	70.000	10.000	2014/03/06	108	2023/03	
	81405	CARBOFURAN	< .0000 UG/L	18.000	5.000	2014/03/06	36	2017/03	
	38432	DALAPON	< .0000 UG/L	200.000	10.000	2014/03/06	36	2017/03	
	77651	ETHYLENE DIBROMIDE (EDB)	< .0000 UG/L	0.050	0.020	2011/05/05	108	2020/05	
	39410	HEPTACHLOR	< .0000 UG/L	0.010	0.010	2011/05/05	108	2020/05	
	39420	HEPTACHLOR EPOXIDE	< .0000 UG/L	0.010	0.010	2011/05/05	108	2020/05	
	39480	METHOXYCHLOR	< .0000 UG/L	30.000	10.000	2011/05/05	108	2020/05	
	39032	PENTACHLOROPHENOL	< .0000 UG/L	1.000	0.200	2014/03/06	36	2017/03	
	39720	PICLORAM	< .0000 UG/L	500.000	1.000	2014/03/06	36	2017/03	
	39400	TOXAPHENE	< .0000 UG/L	3.000	1.000	2011/05/05	108	2020/05	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO: 004

NAME: 2008 WELL

CLASS: CTGA

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES	
2100508 - 004	2100508 MUIR BEACH COMMUNITY	004	2008 WELL							
	GP SECONDARY/GP									
	00440	BICARBONATE ALKALINITY	240.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00916	CALCIUM	34.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00445	CARBONATE ALKALINITY	< 1.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00940	CHLORIDE	33.0000	MG/L	500.000	-----	2014/03/06	36	2017/03	
	00081	COLOR	15.0000	UNITS	15.000	-----	2014/03/06	36	2017/03	
	01042	COPPER	< 50.0000	UG/L	1000.000	50.000	2014/03/06	36	2017/03	
	38260	FOAMING AGENTS (MBAS)	< .0500	MG/L	0.500	-----	2014/03/06	36	2017/03	
	00900	HARDNESS (TOTAL) AS CaCO3	150.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	71830	HYDROXIDE ALKALINITY	< 1.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	01045	IRON	< 100.0	UG/L	300.000	100.000	2016/05/02	3	2016/08	
	00927	MAGNESIUM	15.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	01055	MANGANESE	100.0	UG/L	50.000	20.000	2016/05/02	3	2016/08	
	00086	ODOR THRESHOLD @ 60 C	< 1.0000	TON	3.000	1.000	2014/03/06	36	2017/03	
	00403	PH, LABORATORY	7.5000		-----	-----	2014/03/06	36	2017/03	
	01077	SILVER	< 10.0000	UG/L	100.000	10.000	2014/03/06	36	2017/03	
	00929	SODIUM	36.0000	MG/L	-----	-----	2014/03/06	36	2017/03	
	00095	SPECIFIC CONDUCTANCE	490.0000	US	1600.000	-----	2014/03/06	36	2017/03	
	00945	SULFATE	19.0000	MG/L	500.000	0.500	2014/03/06	36	2017/03	
	70300	TOTAL DISSOLVED SOLIDS	310.0000	MG/L	1000.000	-----	2014/03/06	36	2017/03	
	82079	TURBIDITY, LABORATORY	2.8000	NTU	5.000	0.100	2014/03/06	36	2017/03	
	01092	ZINC	< 50.0000	UG/L	5000.000	50.000	2014/03/06	36	2017/03	
	IO INORGANIC									
	01105	ALUMINUM	< 50.0000	UG/L	1000.000	50.000	2014/03/06	36	2017/03	
	01097	ANTIMONY	< 6.0000	UG/L	6.000	6.000	2014/03/06	36	2017/03	
	01002	ARSENIC	2.2000	UG/L	10.000	2.000	2014/03/06	36	2017/03	
	81855	ASBESTOS	ND	MFL	7.000	0.200	2008/12/08	108	2017/12	
	01007	BARIIUM	150.0000	UG/L	1000.000	100.000	2014/03/06	36	2017/03	
	01012	BERYLLIUM	< 1.0000	UG/L	4.000	1.000	2014/03/06	36	2017/03	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO:

NAME: 2008 WELL

CLASS: CTGA

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES	
2100508 - 004	IO INORGANIC									
	01027	CADMIUM	<	1.0000 UG/L	5.000	1.000	2014/03/06	36	2017/03	
	01034	CHROMIUM (TOTAL)	<	1.0000 UG/L	50.000	10.000	2014/03/06	36	2017/03	
	01032	CHROMIUM, HEXAVALENT	<	.0000 UG/L	10.000	1.000	2014/08/28	36	2017/08	
	00951	FLUORIDE (F) (NATURAL-SOURCE)		.3700 MG/L	2.000	0.100	2014/03/06	36	2017/03	
	71900	MERCURY	<	1.0000 UG/L	2.000	1.000	2014/03/06	36	2017/03	
	01067	NICKEL	<	10.0000 UG/L	100.000	10.000	2014/03/06	36	2017/03	
	A-031	PERCHLORATE	<	4.0000 UG/L	6.000	4.000	2014/03/06	36	2017/03	
	01147	SELENIUM	<	5.0000 UG/L	50.000	5.000	2014/03/06	36	2017/03	
	01059	THALLIUM	<	1.0000 UG/L	2.000	1.000	2014/03/06	36	2017/03	
	NI NITRATE/NITRITE									
	00618	NITRATE (as N)	<	0.4 mg/L	10.000	0.400	2016/02/22	12	2017/02	
	00620	NITRITE (AS N)	<	400.0000 UG/L	1000.000	400.000	2014/03/06	36	2017/03	
	RA RADIOLOGICAL									
	01501	GROSS ALPHA		2.1100 PCI/L	15.000	3.000	2010/06/21	108	2019/06	
	S1 REGULATED VOC									
	34506	1,1,1-TRICHLOROETHANE	<	0.5 UG/L	200.000	0.500	2016/06/28	72	2022/06	
	34516	1,1,2,2-TETRACHLOROETHANE	<	0.5 UG/L	1.000	0.500	2016/06/28	72	2022/06	
	34511	1,1,2-TRICHLOROETHANE	<	0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34496	1,1-DICHLOROETHANE	<	0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34501	1,1-DICHLOROETHYLENE	<	0.5 UG/L	6.000	0.500	2016/06/28	72	2022/06	
	34551	1,2,4-TRICHLOROBENZENE	<	0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34536	1,2-DICHLOROBENZENE	<	0.5 UG/L	600.000	0.500	2016/06/28	72	2022/06	
	34531	1,2-DICHLOROETHANE	<	0.5 UG/L	0.500	0.500	2016/06/28	72	2022/06	
	34541	1,2-DICHLOROPROPANE	<	0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34561	1,3-DICHLOROPROPENE (TOTAL)	<	0.5 UG/L	0.500	0.500	2016/06/28	72	2022/06	
	34571	1,4-DICHLOROBENZENE	<	0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34030	BENZENE	<	0.5 UG/L	1.000	0.500	2016/06/28	72	2022/06	
	32102	CARBON TETRACHLORIDE	<	0.5 UG/L	0.500	0.500	2016/06/28	72	2022/06	
	77093	CIS-1,2-DICHLOROETHYLENE	<	0.5 UG/L	6.000	0.500	2016/06/28	72	2022/06	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO:

NAME: 2008 WELL

CLASS: CTGA

STATUS: Active

PCODE	GROUP/CONSTITUENT IDENTIFICATION	LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES
2100508 - 004	S1 34423	DICHLOROMETHANE	< 0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34371	ETHYLBENZENE	< 0.5 UG/L	300.000	0.500	2016/06/28	72	2022/06	
	46491	METHYL-TERT-BUTYL-ETHER (MTBE)	< .0000 UG/L	13.000	3.000	2014/03/06	36	2017/03	
	34301	MONOCHLOROBENZENE	< 0.5 UG/L	70.000	0.500	2016/06/28	72	2022/06	
	77128	STYRENE	< 0.5 UG/L	100.000	0.500	2016/06/28	72	2022/06	
	34475	TETRACHLOROETHYLENE	< 0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34010	TOLUENE	< 0.5 UG/L	150.000	0.500	2016/06/28	72	2022/06	
	34546	TRANS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	10.000	0.500	2016/06/28	72	2022/06	
	39180	TRICHLOROETHYLENE	< 0.5 UG/L	5.000	0.500	2016/06/28	72	2022/06	
	34488	TRICHLOROFLUOROMETHANE	< 5.0 UG/L	150.000	5.000	2016/06/28	72	2022/06	
	81611	TRICHLOROTRIFLUOROETHANE (FREON 113)	< 10.0 UG/L	1200.000	10.000	2016/06/28	72	2022/06	
	39175	VINYL CHLORIDE	< 0.5 UG/L	0.500	0.500	2016/06/28	72	2022/06	
	81551	XYLENES (TOTAL)	< 0.5 UG/L	1750.000	0.500	2016/06/28	72	2022/06	
S2 REGULATED SOC									
	39045	2,4,5-TP (SILVEX)	< .0000 UG/L	50.000	1.000	2014/03/06	108	2023/03	
	39730	2,4-D	< .0000 UG/L	70.000	10.000	2014/03/06	108	2023/03	
	81405	CARBOFURAN	< .0000 UG/L	18.000	5.000	2014/03/06	36	2017/03	
	38432	DALAPON	< .0000 UG/L	200.000	10.000	2014/03/06	36	2017/03	
	77651	ETHYLENE DIBROMIDE (EDB)	< .0000 UG/L	0.050	0.020	2011/05/05	108	2020/05	
	39410	HEPTACHLOR	< .0000 UG/L	0.010	0.010	2011/05/05	108	2020/05	
	39420	HEPTACHLOR EPOXIDE	< .0000 UG/L	0.010	0.010	2011/05/05	108	2020/05	
	39480	METHOXYCHLOR	< .0000 UG/L	30.000	10.000	2011/05/05	108	2020/05	
	39032	PENTACHLOROPHENOL	< .0000 UG/L	1.000	0.200	2014/03/06	36	2017/03	
	39720	PICLORAM	< .0000 UG/L	500.000	1.000	2014/03/06	36	2017/03	
	39400	TOXAPHENE	< .0000 UG/L	3.000	1.000	2011/05/05	108	2020/05	

LAST SAMPLE DATE AND MONITORING SCHEDULE

SYSTEM NO: 2100508

NAME: MUIR BEACH COMMUNITY

COUNTY: MARIN

SOURCE NO: 006

NAME: DIST - 1851 SHORELINE

CLASS: DBPT

STATUS: Active

PSCODE	GROUP/CONSTITUENT IDENTIFICATION		LAST RESULT	UNITS	MCL	DLR	LAST SAMPLE	FREQ MON THS	NEXT SAMPLE DUE	NOTES
2100508 - 006	2100508	MUIR BEACH COMMUNITY	006	DIST - 1851 SHORELINE						
	D BP	DISINFECTION BYPRODUCTS								
		A-049	HALOACETIC ACIDS (5) (HAA5)	2.83	UG/L	60.000	-----	2015/10/19	32	2018/06
	82080	TOTAL TRIHALOMETHANES	25.3	UG/L	80.000	-----	2015/10/19	32	2018/06	